# <u>Annex – 2 Fixed Fire Fighting Systems</u>

# **Summary of Maintenance, Testing and Inspection Intervals**

| Aerosol fire-extinguishing systems  | Regulation                          | Ship<br>Type | Interval  | Ву    | Remarks |
|---|-------------------------------------|--------------|-----------|-------|---------|
| Verify all electrical connections/and/or manual operating stations are properly arranged, and are in proper condition.  | MSC.1/Circ. 1432,<br>para 5.7.1     | All          | Monthly   | Ship  |         |
| Verify the actuation system/control panel circuits are within manufacturer's specifications.  | MSC.1/Circ. 1432,<br>para 5.7.2     | All          | Monthly   | Ship  |         |
| Verify that condensed or dispersed aerosol generators have not exceeded their mandatory replacement date. Pneumatic or electric actuators shall be demonstrated working, as far as practicable. | MSC.1.Circ. 1432,<br>para 7.10      | All          | Annually  | Ship  |         |
| Condensed or dispersed aerosol generators to be renewed in accordance with manufacturer's recommendations   | MSC.1/Circ. 1432,<br>para 10.4      | All          | 10-yearly | Shore |         |
| Fixed gas fire fighting system<br>other than CO2<br>(e.g. FM200, NOVEC 1230)  | Regulation                          | Ship<br>Type | Interval  | Ву    | Remarks |
| Verify all fixed fire-extinguishing system control panel indicators are functional by operating the lamp/indicator test switch  | Msc.1/Circ.<br>1432, Para.<br>4.2.1 | All          | Weekly    | Ship  |         |
| Verify that all control/section valves are in the correct position  | MSC.1/Circ. 1432,<br>para 4.2.2     | All          | Weekly    | Ship  |         |
| Verify containers/cylinders fitted  | MSC.1/Circ. 1432,                   | All          | Monthly   | Ship  |         |

|   | with procesure gauges are in the       | noro F 3           |       |   |         |  |
|---|--|--------------------|-------|---|---------|--|
|   | with pressure gauges are in the        | para 5.2           |       |   |         |  |
|   | proper range and the installation      |                    |       |   |         |  |
|   | free from leakage                      | 1100 1 /0: 1100    | • 11  |   | 01.1    |  |
|   | Visually inspect all accessible        | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | components for proper condition        | para 7.3.1         |       |   |         |  |
|   | Externally examine all high pressure   | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | cylinders for evidence of damage of    | para 7.3.2         |       |   |         |  |
|   | corrosion                              |                    |       |   |         |  |
|   | Check the hydrostatic test date of all | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | storage containers                     | para 7.3.3         |       |   |         |  |
|   | Functionally test all fixed system     | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | audible and visual alarms.             | para 7.3.4         |       | ,                                       | ·       |  |
|   | Verify all control/section valves are  | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | in the correct position.               | para 7.3.5         |       | ,                                       | •       |  |
|   | Check the connections of all pilot     | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | release piping and tubing for          | para 7.3.6         |       | , |         |  |
|   | tightness.                             | pa. a. 7.0.0       |       |   |         |  |
|   | Examine all flexible hoses in          | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | accordance with manufacturer's         | para 7.3.7         | 7     | 7                                       | 3p      |  |
|   | recommendations.                       | para 7.5.7         |       |   |         |  |
|   | Test all fuel shut-off controls        | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | connected to fire-protection systems   | para 7.3.8         | 7 111 | 7 timadily                              | 3111p   |  |
|   | for proper operation                   | para 7.5.0         |       |   |         |  |
|   | The boundaries of the protected        | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | space should be visually inspected to  | para 7.3.9         | All   | Aillidally                              | Silip   |  |
|   | confirm that no modifications have     | para 7.3.9         |       |   |         |  |
|   | been made to the enclosure that has    |                    |       |   |         |  |
|   |  |                    |       |   |         |  |
|   | created uncloseable openings that      |                    |       |   |         |  |
|   | would render the system ineffective.   | NACC 4 /Circ 4 422 | A II  | A                                       | Ch:     |  |
|   | If cylinders are installed inside the  | MSC.1/Circ. 1432,  | All   | Annually                                | Ship    |  |
|   | protected space, verify the integrity  | para 7.3.10        |       |   |         |  |
|   | of the double release lines inside the |                    |       |   |         |  |
|   | protected space, and check low         |                    |       |   |         |  |
|   | pressure or circuit integrity monitors |                    |       |   |         |  |
| ļ | on release cabinet, as applicable.     |                    |       |   |         |  |
|   | All high pressure extinguishing        | MSC.1/Circ. 1432,  | All   | 2-yearly                                | Ship or |  |
|   | agents cylinders and pilot cylinders   | para 8.1.1         |       |   | Shore   |  |
|   | should be weighed or have their        |                    |       |   |         |  |

| contents verified by other reliable means to confirm that the available charge in each is above 95 per cent of the nominal charge. Cylinders containing less than 95 per cent of  |                                  |      |                        |             |         |
|---|----------------------------------|------|------------------------|-------------|---------|
| the nominal charge should be refilled  Blow dry compressed air or nitrogen  | MSC.1/Circ. 1432,                | All  | 2-yearly               | Ship or     |         |
| through the discharge piping or otherwise confirm the pipe work and nozzles are clear of any obstructions.  This may require the removal of nozzles, if applicable.   | para 8.1.2                       | All  | z-yeariy               | Shore       |         |
| Perform internal inspection of all control valves   | MSC.1/Circ. 1432,<br>para 9.1    | All  | 5-yearly               | Shore       |         |
| Perform a hydrostatic test and internal examination of 10 percent of the system's extinguishing agent and pilot cylinders. If one or more cylinders fail, a total of 50 per cent of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested. If permitted by the Administration, visual examination and NDT of Halon cylinders may be performed in lieu of hydrostatic testing. | MSC.1/Circ. 1432, para 10.1.1    | All  | 10-yearly              | Shore Shore |         |
| Flexible hoses should be replaced at the intervals recommended by the manufacturer and not exceeding every 10 years   | MSC.1/Circ. 1432,<br>para 10.1.2 | All  | At least 10-<br>yearly | Ship/ Shore |         |
| CO2 fire-extinguishing  | Regulation                       | Ship | Interval               | Ву          | Remarks |
| systems   |                                  | Туре |                        |             |         |
| General visual inspection of the overall system condition for obvious signs of damage.  | MSC.1/Circ. 1318,<br>para 41     | All  | Monthly                | Ship        |         |
| Verify that all stop valves are in the closed position  | MSC.1/Circ. 1318,<br>para 4.1.1  | All  | Monthly                | Ship        |         |

| Verify that all releasing controls are in the proper position and readily accessible for immediate use.   | MSC.1/Circ. 1318,<br>para 4.1.2 | All | Monthly  | Ship |                            |
|---|---------------------------------|-----|----------|------|----------------------------|
| Verify all discharge piping and pneumatic tubing is intact and has not been damaged   | MSC.1/Circ. 1318,<br>para 4.1.3 | All | Monthly  | Ship |                            |
| Verify that all high pressure cylinders are in place and properly secured   | MSC.1/Circ. 1318,<br>para 4.1.4 | All | Monthly  | Ship |                            |
| Verify that the alarm devices are in place and do not appear damaged.   | MSC.1/Circ. 1318,<br>para 4.1.5 | All | Monthly  | Ship |                            |
| In addition, for Low Pressur  | •                               | L   |          |      | 1                          |
| Verify that the pressure gauge is reading in the normal range   | MSC.1/Circ. 1318,<br>para 4.2.1 | All | Monthly  | Ship | Low Pressure CO2<br>system |
| Verify that the liquid level indicator is reading within the proper level.  | MSC.1/Circ. 1318,<br>para 4.2.2 | All | Monthly  | Ship | Low Pressure CO2<br>system |
| Verify that the manually operated storage tank main service valve is secured in the open position.  | MSC.1/Circ. 1318,<br>para 4.2.3 | All | Monthly  | Ship | Low Pressure CO2<br>system |
| Verify that the vapour supply line valve is secured in the open position.   | MSC.1/Circ. 1318,<br>para 4.2.4 | All | Monthly  | Ship | Low Pressure CO2<br>system |
| The boundaries of the protected space should be visually inspected to confirm that no modifications have been made to the enclosure that have created unclose able openings that would render the system ineffective  | MSC.1/Circ. 1318,<br>para 5.1   | All | Annually | Ship |                            |
| All storage containers should be visually inspected for any signs of damage, rust or loose mounting hardware. Cylinders that are leaking, corroded, dented or bulging should be hydrostatically retested or replaced. | MSC.1/Circ. 1318,<br>para 5.2   | All | Annually | Ship |                            |
| System piping should be visually inspected to check for damage, loose supports and corrosion. Nozzles   | MSC.1/Circ. 1318,<br>para 5.3   | All | Annually | Ship |                            |

| should be inspected to ensure they have not been obstructed by the storage of spare parts or a new installation of structure or machinery.  The manifold should be inspected to verify that all flexible discharge hoses and fittings are properly tightened.   | MSC.1/Circ. 1318,<br>para 5.4   | All                | Annually  | Ship  |  |
|---|---------------------------------|--------------------|---|-------|--|
| All entrance doors to be protected space should close properly and should have warning signs, which indicate that the space is protected by a fixed carbon dioxide systems and that personnel shall evacuate immediately if the alarms sound. All remote releasing controls shall be checked for clear operating instructions and indication as to the space served | MSC.1/Circ. 1318,<br>para 5.5   | All                | Annually  | Ship  |  |
| All high pressure cylinders and pilot cylinders shall be weighed or have their contents verified by other reliable means to confirm that the available charge in each is above 90% of the nominal charge. Cylinders   | MSC.1/Circ. 1318,<br>para 6.1.1 | Passenger<br>ships | 2-yearly+-<br>3months   | Shore |  |
| containing less than 90% of the nominal charge should be refilled.  Low pressure CO2 System: The liquid level of low pressure storage tanks should be checked to verify that the required amount of carbon dioxide to protect the largest hazards is available.   |                                 | Cargo<br>ships     | During<br>periodical/<br>intermediate<br>and renewal<br>surveys | Shore |  |
| The hydrostatic test date of all storage containers should be   | MSC.1/Circ. 1318,<br>para 6.1.2 | Passenger<br>ships | 2-yearly+- 3<br>months  | Shore |  |
| checked   |                                 | Cargo<br>ships     | During<br>periodical/<br>intermediate                           | Shore |  |

|  |  |                                 |                    | and renewal surveys                                 |       |  |
|--|--|---------------------------------|--------------------|---|-------|--|
| not blocked. The   | verify that they are   | MSC.1/Circ. 1318,<br>para 6.1.3 | Passenger<br>ships | 2-yearly +-3<br>months                              | Shore |  |
| from the system or nitrogen from   | and flowing dry air  |                                 | Cargo<br>Ships     | During periodical/ intermediate and renewal surveys | Shore |  |
| the cylinder val   | , all activating<br>e removed from<br>ves and tested for<br>ning by applying   | MSC.1/Circ. 1318,<br>para 6.2.1 | Passenger<br>ships | 2-yearly +-3<br>months                              | Shore |  |
| full working prepilot lines. In case where to pilot lines shall from the cylind blanked off or contogether and to working pressurelease station leakage. In both cases the out from one of stations when in the station leakage when it is manual pull contogether and correspond condition and do not required. | his is not possible, be disconnected er valves and connected ested with full re from the and checked for his shall be carried r more release installed. ables operate the controls, they |                                 | Cargo<br>Ships     | At least 5-<br>yearly                               | Shore |  |

| All cable components should be cleaned and adjusted as necessary, and the cable   | MSC.1/Circ. 1318,<br>para 6.2.2 | Passenger<br>ships      | 2-yearly+-<br>3months    | Shore |  |
|---|---------------------------------|-------------------------|--------------------------|-------|--|
| connectors shall be properly tightened, If the remote release controls are operated by pneumatic pressure, the tubing shall be checked for leakage, and the proper charge of the remote releasing station pilot gas cylinders shall be verified. All controls and warning devices shall function normally, and the time delay, if fitted shall prevent the discharge of gas for the required time period. |                                 | Cargo<br>Ships          | At least 5-<br>yearly    | Shore |  |
| After completion of the work, the system shall be returned to   | MSC.1/Circ. 1318,<br>para 6.2.3 | Passenger               | 2-yearly+-3              | Shore |  |
| service. All releasing controls shall be verified in the proper position and connected to the correct control valves. All pressure switch interlocks shall be rest and returned to service. All stops valves shall be in the closed position.   |                                 | Ships<br>Cargo<br>Ships | months At least 5 yearly | Shore |  |
| High pressure cylinders shall be subjected to periodical tests at intervals not exceeding 10 years. At the 10-years inspection, at least 10% of the total number provided should be subjected to an internal inspection and hydrostatic test. If one or more cylinders fail, a total of 50% of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested.         | MSC.1/Circ. 1318,<br>para 6.1.2 | AII                     | 10-yearly                | Shore |  |

| Flexible hoses shall be replaced at the intervals recommended by the manufacturer and not exceeding 10 years                           | MSC.1/Circ. 1318,<br>para 6.1.2  | All          | At least 10-<br>yearly | Ship /<br>Shore |         |
|--|----------------------------------|--------------|------------------------|-----------------|---------|
| Dry Chemical powder systems  | Regulation                       | Ship<br>Type | Interval               | Ву              | Remarks |
| Verify that all control and section valves are in the proper open or closed position, and all pressure gauges are in the proper range. | MSC.1/Circ. 1432,<br>Para 5.6    | All          | Monthly                | Ship            |         |
| Visually inspect all accessible components for proper condition.   | MSC.1/Circ. 1432,<br>Para 7.9.1  | All          | Annually               | Ship            |         |
| Verify that the pressure regulators are in proper order and within calibration   | MSC.1/Circ. 1432,<br>Para 7.9.2  | All          | Annually               | Ship            |         |
| Agitate the dry chemical powder charge with nitrogen in accordance with system manufacturer's instructions                             | MSC.1/Circ. 1432,<br>Para 7.9.3  | All          | Annually               | Ship            |         |
| Blow dry nitrogen through the discharge piping to confirm that the pipe work and nozzles are clear of any obstructions.                | MSC.1/Circ. 1432,<br>Para 8.2.1. | All          | 2-yearly               | Shore           |         |
| Operationally test local and remote controls and section valves.   | MSC.1/Circ. 1432,<br>Para 8.2.2  | All          | 2-yearly               | Shore           |         |
| Verify the contents of propellant gas cylinders (including remote operating stations).   | MSC.1/Circ. 1432,<br>Para 8.2.3  | All          | 2-yearly               | Shore           |         |
| Test a sample of dry chemical powder for moisture content.   | MSC.1/Circ. 1432,<br>Para 8.2.4  | All          | 2-yearly               | Shore           |         |
| Subject the powder containment vessel, safety valve and discharge hoses to a full working pressure test                                | MSC.1/Circ. 1432,<br>Para 8.2.5  | All          | 2-yearly               | Shore           |         |

| Subject all powder containment vessels to hydrostatic or non-destructive testing (NDT) carried out by an accredited service agent.  | MSC. 1/Circ.<br>1432, para. 10.3  | All          | 10-yearly | Shore |         |
|---|-----------------------------------|--------------|-----------|-------|---------|
| Foam Fire-Extinguishing systems   | Regulation                        | Ship<br>Type | Interval  | Ву    | Remarks |
| Verify that all controls and section valves are in the proper open or closed position, and all pressure gauges are in the proper range.   | MSC. 1/Circ.<br>1432, para.5.3    | All          | Monthly   | Ship  |         |
| Verify that the proper quantity of foam concentrate is provided in the foam system storage tank.  | MSC. 1/Circ.<br>1432, para.6.2    | All          | Quarterly | Ship  |         |
| Visually inspect all accessible components for proper condition.  | MSC. 1/Circ.<br>1432, para 7.4.1. | All          | Annually  | Ship  |         |
| Functionally test all fixed system audible alarms   | MSC. 1/Circ.<br>1432, para.7.4.2  | All          | Annually  | Ship  |         |
| Flow test all water supply and foam pumps for proper pressure and capacity, and confirm flow at the required pressure in each section (Ensure all piping is thoroughly flushed with fresh water after service). | MSC. 1/Circ.<br>1432, para.7.4.3  | All          | Annually  | Ship  |         |
| Test all system cross connections to other sources of water supply for proper operation.  | MSC. 1/Circ.<br>1432, para.7.4.4  | All          | Annually  | Ship  |         |
| Verify all pump relief valves, if provided, are properly set.   | MSC. 1/Circ.<br>1432, para.7.4.5  | All          | Annually  | Ship  |         |
| Examine all filters/strainers to verify they are free of debris and contamination.  | MSC. 1/Circ.<br>1432, para.7.4.6  | All          | Annually  | Ship  |         |

| Verify that all control/section valves are in the correct position.   | MSC. 1/Circ.<br>1432, para.7.4.7  | All | Annually  | Ship  |  |
|---|-----------------------------------|-----|---|-------|--|
| Blow dry compressed air or nitrogen through the discharge piping or otherwise confirm the pipe work and nozzles of high expansion foam systems are clear of any obstructions, debris and contamination. This may require the removal of nozzles, if applicable. | MSC. 1/Circ.<br>1432, para.7.4.8  | All | Annually  | Ship  |  |
| Foam Concentrates: The first periodical control of foam concentrates should be performed not more than 3 years after being supplied to the ship, and after that every year (except protein)   | MSC.1/Circ.1312,<br>para 5        | All | 3 years after<br>supplying<br>and after<br>that every<br>year | Shore |  |
| Foam Concentrates: For protein based alcohol resistant foam concentrates – test to be performed prior to delivery to the ship and annually thereafter.  | MSC.1/Circ.1312,<br>para 5        | All | Prior<br>delivery and<br>then every<br>year                   | Shore |  |
| Test all fuel shut-off controls connected to fire protection system for proper operation.   | MSC. 1/Circ.<br>1432, para.7.4.10 | All | Annually  | Ship  |  |
| Perform internal inspection of all control valves.  | MSC. 1/Circ.<br>1432, para.9.2.1  | All | 5-yearly  | Shore |  |
| Flush all high expansion foam system piping with fresh water, drain and purge with air.   | MSC. 1/Circ.<br>1432, para.9.2.2  | All | 5-yearly  | Shore |  |
| Check all nozzles to prove they are clear of debris   | MSC. 1/Circ.<br>1432, para.9.2.3  | All | 5-yearly  | Shore |  |

| Test all foam proportioners or other foam mixing devices to confirm that the mixing ratio tolerance is within +30 to -10% of the nominal mixing ratio defined by the system approval.                             | MSC. 1/Circ.<br>1432, para.9.2.4  | All          | 5-yearly | Shore |         |
|---|-----------------------------------|--------------|----------|-------|---------|
| Water mist, water spray and sprinkler systems   | Regulation                        | Ship<br>Type | Interval | Ву    | Remarks |
| Verify that all control panel indicators and alarms are functional.   | MSC. 1/Circ.<br>1432, para 4.7.1  | All          | Weekly   | Ship  |         |
| Visually inspect pump unit and its fittings   | MSC. 1/Circ.<br>1432, para 4.7.2  | All          | Weekly   | Ship  |         |
| Check the pump unit valve positions, if valves are not locked, as applicable.   | MSC. 1/Circ.<br>1432, para 4.7.3. | All          | Weekly   | Ship  |         |
| Verify all control, pump unit and section valves are in the proper open or closed position.   | MSC. 1/Circ.<br>1432, para 5.4.1  | All          | Monthly  | Ship  |         |
| Verify sprinkler pressure tanks or other means have correct levels of water.  | MSC. 1/Circ.<br>1432, para 5.4.2  | All          | Monthly  | Ship  |         |
| Test automatic starting arrangements on all system pumps so designed.   | MSC. 1/Circ.<br>1432, para 5.4.3  | All          | Monthly  | Ship  |         |
| Verify that all standby pressure and air/gas pressure gauges are within the proper pressure ranges.   | MSC. 1/Circ.<br>1432, para 5.4.4  | All          | Monthly  | Ship  |         |
| Test a selected sample of system section valves for flow and proper initiation of alarms (Note – The valves selected for testing should be chosen to ensure that all valves are tested within a one-year period.) | MSC. 1/Circ.<br>1432, para 5.4.5  | All          | Monthly  | Ship  |         |

| Assess system water quality in the header tank and pump unit against the manufacturer's water quality guidelines.   | MSC.1/Circ. 1432<br>as amended by<br>MSC.1/Circ.1516,<br>para 2 (6.5) | All | Quarterly | Ship | Water sprinkler<br>system only |
|---|---|-----|-----------|------|--------------------------------|
| Verify proper operation of all water mist, water-spray and sprinkler system using the test valves for each section.   | MSC. 1/Circ.<br>1432, para 7.5.1                                      | All | Annually  | Ship |                                |
| Visually inspect all accessible components for proper condition   | MSC. 1/Circ.<br>1432, para 7.5.2                                      | All | Annually  | Ship |                                |
| Externally examine all high pressure cylinders for evidence of damage or corrosion  | MSC. 1/Circ.<br>1432, para 7.5.3                                      | All | Annually  | Ship |                                |
| Check the hydrostatic test date of all high pressure cylinders.   | MSC. 1/Circ.<br>1432, para 7.5.4                                      | All | Annually  | Ship |                                |
| Functionally test all fixed system audible and visual alarms  | MSC. 1/Circ.<br>1432, para 7.5.5                                      | All | Annually  | Ship |                                |
| Flow test all pumps for proper pressure and capacity  | MSC. 1/Circ.<br>1432, para 7.5.6                                      | All | Annually  | Ship |                                |
| Test all antifreeze systems for adequate freeze protection.   | MSC. 1/Circ.<br>1432, para 7.5.7                                      | All | Annually  | Ship |                                |
| Test all system cross connections to other sources of water supply for proper operation.  | MSC. 1/Circ.<br>1432, para 7.5.8                                      | All | Annually  | Ship |                                |
| Verify all pump relief valves, if provided, are properly set.   | MSC. 1/Circ.<br>1432, para 7.5.9                                      | All | Annually  | Ship |                                |
| Examine all filters/strainers to verify they are free of debris and contamination   | MSC. 1/Circ.<br>1432, para 7.5.10                                     | All | Annually  | Ship |                                |
| Verify that all control/section valves are in the correct position.   | MSC. 1/Circ.<br>1432, para 7.5.11                                     | All | Annually  | Ship |                                |
| Blow dry compressed air or nitrogen through the discharge piping of dry pipe systems or otherwise confirm the pipe work and nozzles are clear of any obstructions. This may require | MSC. 1/Circ.<br>1432, para 7.5.12                                     | All | Annually  | Ship |                                |

| the removal of nozzles, if  |  |      |          |      |             |
|---|--|------|----------|------|-------------|
| applicable.   | NASC 4/C:  | A.II |          | CI.  |             |
| Test emergency power supply switchover, where applicable  | MSC. 1/Circ.<br>1432, para 7.5.13  | All  | Annually | Ship |             |
| Visually inspect all sprinklers focusing in areas where sprinklers are subject to aggressive atmosphere (like saunas, spas, kitchen areas) and subject to physical damage (like luggage handling areas, gyms, play rooms, etc) so that all sprinklers are inspected within one year. Sprinklers with obvious external damage, including paint, should be replaced and not included in the number of sprinklers tested in accordance with the flow charts Part 1 – Basic Testing and Part 2 – Extended Testing as indicated in MSC. 1/Circ. 1516 |  | All  | Annually | Ship | See Annex 1 |
| Check for any changes that may affect the system such as obstructions by ventilation ducts pipes, etc.  | MSC. 1/Circ.<br>1432, para 7.5.15  | All  | Annually | Ship |             |
| Test a minimum of one section in each open head water mist system by flowing water through the nozzle. The section tested should be chosen so that all sections are tested within a five-year period.   | 1432, para 7.5.16  | All  | Annually | Ship |             |
| Test automatic sprinklers and automatic water mist nozzles in accordance with the flow charts Part 1 – Basic Testing and Part 2 – Extended Testing as indicated in MSC. 1/Circ. 1516  | MSC.1/Circ. 1432<br>as amended by<br>MSC.1/Circ.1516,<br>para 3 (7.5.17) | All  | Annually | Ship |             |

|                                    |                   |     |               |         | T               |
|------------------------------------|-------------------|-----|---------------|---------|-----------------|
| During basic testing, and          | MSC.1/Circ. 1432  | All | Annually      | Ship    |                 |
| extended testing when              | as amended by     |     |               |         |                 |
| applicable, of automatic sprinkler | MSC.1/Circ.1516,  |     |               |         |                 |
| heads/nozzles as outlined above,   | para 3 (7.5.18)   |     |               |         |                 |
| water quality testing should be    |                   |     |               |         |                 |
| conducted in each corresponding    |                   |     |               |         |                 |
| piping section.                    |                   |     |               |         |                 |
| Flush all ro-ro deck deluge        | MSC. 1/Circ.      | All | 5-yearly      | Shore   |                 |
| system piping with water, drain    | 1432, para 9.3.1  |     | , ,           |         |                 |
| and purge with air.                | , , , , , , , ,   |     |               |         |                 |
| Perform internal inspection of all | MSC. 1/Circ.      | All | 5-yearly      | Shore   |                 |
| control/section valves; water      | 1432, para 9.3.2  | ,   | 3 / 5 4 1 1 1 | 31.01.0 |                 |
| quality testing should be          | 1 132, para 3.3.2 |     |               |         |                 |
| conducted in all corresponding     |                   |     |               |         |                 |
| piping section, if not previously  |                   |     |               |         |                 |
| tested within the last five year.  |                   |     |               |         |                 |
| Check condition of any batteries,  | MSC. 1/Circ.      | All | 5-yearly      | Shore   |                 |
| or renew in accordance with        | 1432, para 9.3.3  | All | 3 yearry      | 311010  |                 |
| manufacturer's                     | 1432, para 3.3.3  |     |               |         |                 |
| recommendations                    |                   |     |               |         |                 |
| For each section where the water   | MSC.1/Circ. 1432  | All | 5-yearly      | Shore   | Water sprinkler |
|                                    | •                 | All | 5-yearry      | Silore  |                 |
| is refilled after being drained or | as amended by     |     |               |         | system only     |
| flushed, water quality should      | MSC.1/Circ.1516,  |     |               |         |                 |
| meet manufacturer's guidelines.    | para 4 (9.3.4)    |     |               |         |                 |
| Testing of the renewed water       |                   |     |               |         |                 |
| quality should be conducted and    |                   |     |               |         |                 |
| recorded as a new baseline         |                   |     |               |         |                 |
| reference to assist future water   |                   |     |               |         |                 |
| quality monitoring for each        |                   |     |               |         |                 |
| corresponding section.             |                   |     |               |         |                 |
| Perform a hydrostatic test and     | MSC. 1/Circ.      | All | 10-yearly     | Shore   |                 |
| internal examination for gas and   | 1432, para 10.2   |     |               |         |                 |
| water pressure cylinders           |                   |     |               |         |                 |
| according to flag Administration   |                   |     |               |         |                 |
| guidelines or, where these do not  |                   |     |               |         |                 |
| exist, EN 1968:2002 +A1            |                   |     |               |         |                 |

# Flag States Specific Requirements:

| 1 | Marshall Islands  | Ref                           | Ship | Interval  | Ву   | Remarks  |
|---|---|-------------------------------|------|---|--|--|
| _ | Iviai siiaii isiaiias   | Document                      | Туре |   | -  |  |
| A | Fixed CO2 extinguishing systems shall be checked by an authorized service facility acceptable to the vessel's Classification Society  | Marine Notice No.<br>2-011-14 | All  | 2 yearly  | Shore  |  |
| В | At least once every five (5) years, all control valves of fixed CO2 systems are to be internally examined.  | Marine Notice No.<br>2-011-14 | All  | 5 yearly  | Shore  |  |
| С | Halon System: The content of the Halon cylinders should be weighed or have their contents verified by other reliable means to confirm that the available charge in each is above 95% of the nominal charge as far as reasonable and practicable. Cylinders containing less than 95% of the nominal charge should be refilled.   | Marine Notice No.<br>2-011-14 | All  | at least<br>biennially (2<br>years +/- 3<br>months  | Shore  |  |
| D | Hydrostatic testing of all halon cylinders to be carried out. Visual inspection and NDT may be performed in lieu of hydrostatic testing subject to approval by Administration, by an authorized servicing facility which has been certified by a government agency or Classification Society. (maintenance & inspection of Halon system to be asper co2 system) Relaxation- Consideration for the application of the relaxed hydrostatic testing requirements | Marine Notice No.<br>2-011-14 | All  | After each 20 years of service prior to recharging a discharged cylinder any potential defect found | an authorized service facility certified by government agency or class society | Relaxation for hydro testing beyond 20 year as per administration prior approval |

|   |                                      |                     | T                      | T                           | T                        | T             |
|---|--------------------------------------|---------------------|------------------------|-----------------------------|--------------------------|---------------|
|   | for the fixed Halon system storage   |                     |                        |                             |                          |               |
|   | cylinders will be given on a case by |                     |                        |                             |                          |               |
|   | case basis, and must be approved     |                     |                        |                             |                          |               |
|   | in writing by the Administration.    |                     |                        |                             |                          |               |
|   | The hydrostatic testing interval of  |                     |                        |                             |                          |               |
|   | 20 years for the Halon cylinder      |                     |                        |                             |                          |               |
|   | may be extended by 5 year            |                     |                        |                             |                          |               |
|   | extension based on following-        |                     |                        |                             |                          |               |
|   | cylinder content verified, cylinder  |                     |                        |                             |                          |               |
|   | not discharge in service, no visual  |                     |                        |                             |                          |               |
|   | defect, cylinder pressure level      |                     |                        |                             |                          |               |
|   | verified, each cylinder gauged or    |                     |                        |                             |                          |               |
|   | NDT to determine wall thickness      |                     |                        |                             |                          |               |
|   | .NDT report to be placed onboard.    |                     |                        |                             |                          |               |
|   | Examination of all accessible        |                     |                        |                             |                          |               |
|   | component, include control and       |                     |                        |                             |                          |               |
|   | connection to verify satisfactory    |                     |                        |                             |                          |               |
|   | condition and also selected valve    |                     |                        |                             |                          |               |
|   | to open for internal examination.    |                     |                        |                             |                          |               |
|   | If any cylinder do not meet          |                     |                        |                             |                          |               |
|   | relaxation requirement than must     |                     |                        |                             |                          |               |
|   | be hydro tested or taken out of      |                     |                        |                             |                          |               |
|   | service, if cylinder removed than    |                     |                        |                             |                          |               |
|   | system still be capable of           |                     |                        |                             |                          |               |
|   | supplying fire extinguisher. The     |                     |                        |                             |                          |               |
|   | inspection requirement to be done    |                     |                        |                             |                          |               |
|   | annually including NDT until end of  |                     |                        |                             |                          |               |
|   | 5 year period.                       |                     |                        |                             |                          |               |
| E | Water Mist, Water Spray, and S       | prinkler Systems: 7 | I<br>Ten yearly hydros | I<br>Static test and interi | I<br>nal examination for | gas and water |
|   | pressure cylinders shall be conduct  | •                   | • • •                  |                             |                          |               |
|   | Steel Gas Cylinders (EN 1968:2002    |                     | •                      | •                           | •                        | Ŭ             |
|   |                                      | ,, or offering on   |                        | ,                           |                          |               |
|   |                                      |                     |                        |                             |                          |               |
|   |                                      |                     |                        |                             |                          |               |
|   |                                      |                     |                        |                             |                          |               |
|   |                                      |                     |                        |                             |                          |               |
|   |                                      |                     |                        |                             |                          |               |
|   |                                      |                     |                        |                             |                          |               |

| 2 | Bahamas  | Ref                                 | Ship         | Interval                   | Ву    | Remarks     |
|---|--|-------------------------------------|--------------|----------------------------|-------|-------------|
|   |  | Document                            | Type         |                            |       |             |
| A | Fixed CO2 extinguishing systems: At least once every five (5) years, all control valves of fixed CO2 systems are to be internally examined.                              | Information<br>Bulletin No. 150     | All          | 5 yearly                   | Shore |             |
| В | Automatic Sprinkler System: All initial and basic testing shall be conducted onboard for sprinkler as per 150  | Information<br>Bulletin No. 150     | All          | During<br>Annual<br>Survey |       | See Annex 1 |
|   | Extended testing shall be conducted onboard  | Information<br>Bulletin No. 150     | All          | During<br>Annual<br>Survey |       | See Annex 1 |
|   | Water quality shall be assessed through periodic sampling and analysis in accordance with manufacturer's instructions  | Information<br>Bulletin No. 150     | All          | Periodically               |       |             |
| 3 | Liberia  | Ref<br>Document                     | Ship<br>Type | Interval                   | Ву    | Remarks     |
| A | Sprinkler System: All automatic alarms for the sprinkler systems are tested using the test valves for each section.  | Marine Notice FIR-<br>001 Rev.06/12 | All          | Quarterly                  | Ship  |             |
| В | Fixed CO2 extinguishing systems: All CO2 bottle connections for cable operating system clips should be checked for tightness on fixed fire- extinguishing installations. | Marine Notice FIR-<br>001 Rev.06/12 | All          | Quarterly                  | Ship  |             |
| С | At least once every five (5) years, all control valves of fixed CO2 systems are to be internally examined.   | Marine Notice FIR-<br>001 Rev.06/12 | All          | 5 yearly                   | Shore |             |
| D | Existing ship with co2 cylinder 10 year old but less than 20 year  | Marine Notice FIR-<br>001 Rev.06/12 | All          |                            | Shore |             |

|   | cylinder to have hydro tested (At least 10% of the total number of CO2 cylinders should be hydrostatically tested. If one or more cylinders fail, a total of 50% of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested). Co2 cylinder more than 20 year old, not tested so far, have to be hydro tested by next annual or intermediate and to be 50% of onboard. If any fail than all to be tested. |                                     |     |   |                             |  |
|---|--|-------------------------------------|-----|---|-----------------------------|--|
| E | Halon System: All halon cylinders must be hydrostatically tested(maintenance and inspection of Halon system to be as per co2 system)   |                                     |     | After each<br>20 years of<br>service                          |                             | Relaxation for hydro testing beyond 20 year as per administration prior approval |
|   | Relaxation- 5 year extension for<br>the 20 year old cylinder based on<br>following- cylinder content<br>verified, cylinder not discharge in<br>service, no visual defect, cylinder<br>pressure level verified, each<br>cylinder gauged or NDT to<br>determine wall thickness .NDT  | Marine Notice FIR-<br>001 Rev.06/12 | All | prior to<br>recharging a<br>discharged<br>cylinder            | An<br>authorized<br>service |  |
|   | report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to opened for internal examination If any cylinder does not meet relaxation requirement then must be hydro tested or taken out of service, if cylinder removed than system still be capable of supplying fire  |                                     |     | When visual<br>inspection<br>reveals a<br>potential<br>defect | facility                    |  |

|   | extinguisher. This may require replacement or alternate fire extinguishing systems. Inspection requirement to be done annually. The NDT requirement not to be repeated later than 36 month.  Note to be recommended in survey status of vessel regarding same, and this procedure to be done as per flag authorization. |                                     |              |  |             |         |
|---|---|-------------------------------------|--------------|--|-------------|---------|
| F | Fixed Dry Chemical Powder Fire Extinguishing Systems: General examination of distribution piping and installation of the dry chemical powder fire fighting system to confirm that the system has not been modified from its original installation.  | Marine Notice FIR-<br>001 Rev.06/12 | AII          | Each annual,<br>periodic,<br>renewal<br>survey | Ship /Shore |         |
| 4 | Dominica  | Ref<br>Document                     | Ship<br>Type | Interval                                       | Ву          | Remarks |
| Α |   |                                     | / 1          |  |             |         |
|   | All CO2 bottle connections for cable operating system clips should be checked for tightness on fixed fire-extinguishing installations   | CD-MSC 33-01 Rev<br>01              | All          | Quarterly                                      | Ship        |         |
| В | cable operating system clips<br>should be checked for tightness<br>on fixed fire-extinguishing  |                                     | All          | Quarterly Annually                             | Ship        |         |

| D | and recharging is required if the loss in charge is 10 percent or more.  Control valves of fixed fire fighting systems should be internally inspected. | CD-MSC 33-01 Rev<br>01 | All | 5-yearly  | Shore                       |  |
|---|--|------------------------|-----|---|-----------------------------|--|
| E | All fixed CO2 and Halon cylinders must be hydrostatically tested   | CD-MSC 33-01 Rev<br>01 | All | after each 20 years of service prior to recharging a discharged cylinder, if 10 years or more since last hydrostatic test when visual inspection reveals a potential defect | An<br>authorized<br>station |  |
| F | Foam Analysis: Foam analysis is a part of the survey for issuance of the SOLAS Safety Equipment Certificate and thus is performed every two years.     | CD-MSC 33-01 Rev<br>01 | All | Every 2 years (any other times if there is cause to question the suitability of the foam or condition of the storage tank)  | Shore                       |  |

| 5 | Barbados   | Ref                             | Ship | Interval  | Ву    | Remarks |
|---|--|---------------------------------|------|-----------|-------|---------|
|   |  | Document                        | Туре |           |       |         |
| А | Sprinkler System: All automatic alarms for the sprinkler systems are tested using the test valves for each section.  | Information<br>Bulletin No. 230 | All  | Quarterly | Ship  |         |
| В | Fixed CO2 extinguishing systems: All CO2 bottle connections for cable operating system clips should be checked for tightness on fixed fire- extinguishing installations.   | Information<br>Bulletin No. 230 | All  | Quarterly | Ship  |         |
| С | Air should be blown through the piping of extinguishing gas system   | Information<br>Bulletin No. 230 | All  | Annually  | Ship  |         |
| D | Existing ships equipped with storage co2 containers that are 10 years old or older but less than 20 years of age shall have the storage containers hydrostatically tested at latest by the vessel's next intermediate or special survey. (At least 10% of the total number of CO2 cylinders should be hydrostatically tested. If one or more cylinders fail, a total of 50% of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested). | Information<br>Bulletin No. 230 | All  |           | Shore |         |
| E | Low Pressure CO2 Systems: At least once every five years, the control valves of fixed fire-fighting systems should be internally inspected.  | Information<br>Bulletin No. 230 | All  | 5-yearly  | Shore |         |

| F N2 high pressure cylinders shall<br>be subjected to periodical tests<br>at intervals as IMO recommends<br>for CO2 cylinders  | Information<br>Bulletin No. 230 |      |          |    |         |
|--|---------------------------------|------|----------|----|---------|
| 6 Kiribati   | Ref                             | Ship | Interval | Ву | Remarks |
|  | Document                        | Туре |          |    |         |
| be exempted from hydrostatic pressure testing subject to the following:  1. The tank is to be constructed of a material which is not ordinarily prone to corrosion (e.g. Stainless Steel, Aluminium or similar), and  2. Fittings and inspection of the tank are in accordance with Classification Society requirements; and  3. Documentary evidence to show that the tank and associated systems have been inspected and serviced annually. Annual inspection should include removal of insulation and sample inspection in way of pipe and fittings. The insulation and vapour barrier is to be properly reinstated, and  4. The tank shall not be exposed to extremes of temperature or pressure. Such exposure will require | Marine Circular No. 16/2012     | All  |          |    |         |

|   | · · · · · · ·                       | T                   |     |           | 1          |  |
|---|-------------------------------------|---------------------|-----|-----------|------------|--|
|   | regime to be reviewed and           |                     |     |           |            |  |
|   | the Administration should           |                     |     |           |            |  |
|   | be notified in such cases.          |                     |     |           |            |  |
| В | All CO2 bottle connections for      | Marine Circular No. | All | Quarterly | Ship       |  |
|   | cable operating system clips        | 16/2012             |     |           |            |  |
|   | should be checked for tightness     |                     |     |           |            |  |
|   | on fixed fire-extinguishing         |                     |     |           |            |  |
|   | installations                       |                     |     |           |            |  |
| С | Control valves of fixed fire        | Marine Circular No. | All | 5-yearly  | Shore      |  |
|   | fighting systems should be          | 16/2012             |     |           |            |  |
|   | internally inspected.               |                     |     |           |            |  |
| D | Hydrostatic Pressure Testing        |                     |     |           |            |  |
|   | First pressure test within 20       | Marine Circular No. | All |           | an         |  |
|   | years of initial pressure test of   | 16/2012             |     |           | accredited |  |
|   | manufacturer provided annual        | ,                   |     |           | service    |  |
|   | test have been carried out with     |                     |     |           | agent      |  |
|   | satisfactory results                |                     |     |           |            |  |
|   | Subsequent pressure tests of        |                     |     |           |            |  |
|   | 25% of the storage cylinders        |                     |     |           |            |  |
|   | every 5 years thereafter if any     |                     |     |           |            |  |
|   | one cylinder fails whilst test all  |                     |     |           |            |  |
|   | remaining cylinders are to be       |                     |     |           |            |  |
|   | tested                              |                     |     |           |            |  |
|   | If annual visual inspection are     |                     |     |           |            |  |
|   | not carried out or there is no      |                     |     |           |            |  |
|   | record, all cylinders are to be     |                     |     |           |            |  |
|   | hydraulically tested after ten (10) |                     |     |           |            |  |
|   | years and twenty (20) years from    |                     |     |           |            |  |
|   | the date of manufacture and         |                     |     |           |            |  |
|   | every 5 years thereafter            |                     |     |           |            |  |
|   | In order to extend the cylinder     |                     |     |           |            |  |
|   | test period beyond 20 years a       |                     |     |           |            |  |
|   | thorough examination of all         |                     |     |           |            |  |
|   | cylinders to be carried out         |                     |     |           |            |  |
| E | Fixed Foam System: Inspection       | Marine Circular No. | All | 2 yearly  | 20         |  |
| [ | shall be carried out on fixed foam  |                     | AII | 2-yearly  | an         |  |
|   |                                     | 16/2012             |     |           | accredited |  |
|   | extinguishing systems               |                     |     |           | service    |  |
|   |                                     |                     |     |           | agent      |  |

| F        | Halon systems must be inspected and tested   | Marine Circular No.<br>16/2012                    | All                 | Annually                  | an<br>accredited<br>service<br>agent |         |
|----------|--|---|---------------------|---------------------------|--------------------------------------|---------|
|          | During inspection a leak test must be completed and nay cylinders showing signs of leakage, loss of contents 5% from installed quantity, signs of mechanical damage or excessive corrosion must be withdrawn from service. Upon application hydro testing of HALON cylinder hydro testing exemption may be granted by flag, subject to Alternate inspection proposed by RO |   |                     |                           |                                      |         |
|          |  |   |                     |                           |                                      |         |
| 7        | Tuvalu   | Ref<br>Document                                   | Ship<br>Type        | Interval                  | Ву                                   | Remarks |
| <b>7</b> | Tuvalu  All CO2 bottle connections for cable operating system clips should be checked for tightness on fixed fire-extinguishing installations  | Ref<br>Document<br>MARINE CIRCULAR<br>MC-7/2011/1 | Ship<br>Type<br>All | <b>Interval</b> Quarterly | <b>By</b><br>Ship                    | Remarks |
|          | All CO2 bottle connections for cable operating system clips should be checked for tightness on fixed fire-extinguishing  | <b>Document</b> MARINE CIRCULAR                   | Туре                |                           | ,                                    | Remarks |

|   | Any cylinders showing signs of mechanical damage, excessive corrosion or loss of contents exceeding 10% of installed quantity for CO2 should be withdrawn from service and sent ashore for pressure testing and full periodic service and inspection | MARINE CIRCULAR<br>MC-7/2011/1 | AII |          |  |  |
|---|--|--------------------------------|-----|----------|--|--|
| С | Control valves of fixed fire fighting systems should be internally inspected.  | MARINE CIRCULAR<br>MC-7/2011/1 | All | 5-yearly | Shore                                  |  |
| D | Hydrostatic Pressure Testing   | MARINE CIRCULAR<br>MC-7/2011/1 | All |          | an<br>accredited<br>service<br>company |  |
|   | First pressure test within 20 years of initial pressure test of manufacturer provided annual test have been carried out with satisfactory results  |                                |     |          |  |  |
|   | Subsequent pressure tests of 25% of the storage cylinders every 5 years thereafter if any one cylinder fails whilst test all remaining cylinders are to be tested  |                                |     |          |  |  |
|   | If annual visual inspection are not carried out or there is no record, all cylinders are to be hydraulically tested after ten (10) years and twenty (20) years from the date of manufacture and every 5 years thereafter                             |                                |     |          |  |  |

| must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation 5 year extension for the 20 year old cylinder based on following—cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder do not meet relaxation requirement than must be hydro tested or taken out of service, if cylinder removed than  |   |  | T | 1   | 1        |                       | _  |
|---|---|--|---|-----|----------|-----------------------|--|
| thorough examination of all cylinders to be carried out  E Halon System MARINE CIRCULAR All Annually an accredited service company  Halon systems must be inspected and tested  During inspection a leak test must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation- 5 year extension for the 20 year old cylinder based on following- cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder for ont meet relaxation requirement than must be hydro tested or taken out of service, if cylinder removed than |   | · · · · · · · · · · · · · · · · · · ·  |   |     |          |                       |  |
| cylinders to be carried out  Halon System  MARINE CIRCULAR MC-7/2011/1  Annually  an accredited service company  Halon systems must be inspected and tested  During inspection a leak test must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation- 5 year extension for the 20 year old cylinder based on following- cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder ont ont meet relaxation requirement than must be hydro tested or taken out of service, if cylinder permoved than                   |   | test period beyond 20 years a  |   |     |          |                       |  |
| Halon System  MARINE CIRCULAR MC-7/2011/1  Halon systems must be inspected and tested  During inspection a leak test must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation- 5 year extension for the 20 year old cylinder based on following- cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder do not meet relaxation requirement than must be hydro tested or taken out of service, if cylinder promoved than  |   | thorough examination of all  |   |     |          |                       |  |
| MC-7/2011/1  Baccredited service company  Halon systems must be inspected and tested  During inspection a leak test must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service  (Relaxation - 5 year extension for the 20 year old cylinder based on following- cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard.  Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder do not meet relaxation requirement than must be hydro tested or taken out of service, if cylinder removed than   |   | cylinders to be carried out  |   |     |          |                       |  |
| and tested  During inspection a leak test must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation- 5 year extension for the 20 year old cylinder based on following- cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder do not meet relaxation requirement than must be hydro tested or taken out of service, if cylinder removed than  | E |  |   | All | Annually | accredited<br>service |  |
| must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation- 5 year extension for the 20 year old cylinder based on following-cylinder content verified, cylinder not discharge in service, on visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder do not meet relaxation requirement than must be hydro tested or taken out of service, if cylinder removed than   |   |  |   |     |          |                       |  |
| supplying fire extinguisher. The inspection requirement to be done annually including NDT until end of 5 year period.   |   | During inspection a leak test must be completed and any cylinders showing signs of leakage loss of contents 5% from installed quantity signs of mechanical damage or excessive corrosion must be withdrawn from service (Relaxation- 5 year extension for the 20 year old cylinder based on following- cylinder content verified, cylinder not discharge in service, no visual defect, cylinder pressure level verified, each cylinder gauged or NDT to determine wall thickness .NDT report to be placed onboard. Examination of all accessible component, include control and connection to verify satisfactory condition and also selected valve to open for internal examination. If any cylinder do not meet relaxation requirement than must be hydro tested or taken out of service, if cylinder removed than system still be capable of supplying fire extinguisher. The inspection requirement to be done annually including NDT until end of |   |     |          |                       | HALON cylinder hydro testing exemption may be granted by flag, subject to Alternate inspection |


| F | Fixed Foam System: Inspection shall be carried out on fixed foam | MARINE CIRCULAR<br>MC-7/2011/1 | All | 2-yearly | an<br>accredited |  |
|---|--|--------------------------------|-----|----------|------------------|--|
|   | extinguishing systems  | IVIC-7/2011/1                  |     |          | service          |  |
|   | extinguishing systems  |                                |     |          | agent            |  |
|   |  |                                |     |          | ashore           |  |
|   |  |                                |     |          | 4311010          |  |
| G | Low Pressure CO2 Systems: may                                    | MARINE CIRCULAR                | All |          |                  |  |
|   | be exempted from hydrostatic                                     | MC-7/2011/1                    |     |          |                  |  |
|   | pressure testing subject to the                                  |                                |     |          |                  |  |
|   | following:   |                                |     |          |                  |  |
|   | 1. The tank is to be constructed                                 |                                |     |          |                  |  |
|   | of a material which is not                                       |                                |     |          |                  |  |
|   | ordinarily prone to  |                                |     |          |                  |  |
|   | corrosion(e.g. Stainless Steel,                                  |                                |     |          |                  |  |
|   | Aluminium or similar), and                                       |                                |     |          |                  |  |
|   | 2. Fittings and inspection of the                                |                                |     |          |                  |  |
|   | tank are in accordance with                                      |                                |     |          |                  |  |
|   | Classification Society   |                                |     |          |                  |  |
|   | requirements; and  |                                |     |          |                  |  |
|   | 3. Documentary evidence to                                       |                                |     |          |                  |  |
|   | show that the tank and   |                                |     |          |                  |  |
|   | associated systems have been                                     |                                |     |          |                  |  |
|   | inspected and serviced   |                                |     |          |                  |  |
|   | annually. Annual inspection                                      |                                |     |          |                  |  |
|   | should include removal of  |                                |     |          |                  |  |
|   | insulation and sample  |                                |     |          |                  |  |
|   | inspection in way of pipe and                                    |                                |     |          |                  |  |
|   | fittings. The insulation and                                     |                                |     |          |                  |  |
|   | vapour barrier is to be  |                                |     |          |                  |  |
|   | properly reinstated, and   |                                |     |          |                  |  |
|   | 4. The tank shall not be exposed                                 |                                |     |          |                  |  |
|   | to extremes of temperature                                       |                                |     |          |                  |  |
|   | or pressure. Such exposure                                       |                                |     |          |                  |  |
|   | will require the inspection                                      |                                |     |          |                  |  |
|   | and testing regime to be   |                                |     |          |                  |  |
|   | reviewed and the Administration should be                        |                                |     |          |                  |  |
|   |  |                                |     |          |                  |  |
|   | notified in such cases.  |                                |     |          |                  |  |


| 8 | St. Vincent and the Grenadines  | Ref<br>Document                 | Ship<br>Type | Interval                                   | Ву   | Remarks   |
|---|---|---------------------------------|--------------|--|--|---|
| A | Halon is not accepted as fire extinguishing means onboard any ship applying for registration under the SVG Flag since 1 <sup>st</sup> January 2002. Alternate arrangement is required. Halon fire extinguishing system should be replaced by either CO2 or other suitable system. | Circular NO. SOL 006<br>Rev. 10 | All          |  |  | Applicable to<br>ship register<br>since 1 Jan<br>2002 |
|   | Halon System (For existing fixed halon fire extinguishing system)  Hydrostatic Pressure Test or  Thickness Measurement:   |                                 |              |  |  |   |
|   | At least 50% of the Halon bottles should be tested by hydraulic pressure  | Circular NO. SOL 006<br>Rev. 10 | All          | over a<br>maximum<br>period of 10<br>years | an approved service company  an approved service company | For halon<br>banking facility                         |
|   | 100% of the halon bottles should be tested  | Circular NO. SOL 006<br>Rev. 10 | All          | over a<br>maximum<br>period of 20<br>years |  |   |
|   | Halon cylinders should be subject to thickness measurement in lieu of the hydrostatic pressure test as required. at least 50% should be thickness measured  | Circular NO. SOL 006<br>Rev. 10 | All          | over a<br>period of 10<br>years            |  | if banking<br>facility is                             |
|   | 100% of the halon bottles should be thickness measured  | Circular NO. SOL 006<br>Rev. 10 | All          | over a<br>period of 20<br>years            |  | unavailable   |

|    | occasional hydrostatic pressure testing or thickness measurement as applicable may be requested at the discretion of the attending class surveyor conducting the statutory surveys   | Circular NO. SOL 006<br>Rev. 10 | All  |          |    | if evidence<br>exists to cause<br>concern on<br>condition of<br>the cylinders |  |  |
|----|--|---------------------------------|------|----------|----|---|--|--|
| 9  | Panama   | Ref                             | Ship | Interval | Ву | Remarks   |  |  |
|    |  | Document                        | Туре |          |    |   |  |  |
| Α  | Full scale tests of halon fire- extinguishing system onboard ships are prohibited, however leakage check shall be carried out annually. If any of the cylinders showing signs of leakage and loss of content exceeds 5% from the installed quantity, signs of mechanical damage or excessive corrosion must be withdrawn from service.  MMC-281  All  Annual  chief engineer (if provided with proper equipment and training)  |                                 |      |          |    |   |  |  |
| В  | Fixed dry chemical powder  system: subject all powder containment vessels to hydrostatic or non destructive testing  MMC-281  All  10-yearly by accredicated service agent   |                                 |      |          |    |   |  |  |
| 10 | India (Engineering Circular No.6 of 2013)  |                                 |      |          |    |   |  |  |
| A  | Fixed CO2 system: At the 10 year inspection, at least 10% of the total number of CO2 cylinders should be subjected to an internal inspection and Hydrostatic test. If one or more cylinders fail, a total of 50% of the onboard cylinders should be tested. If further cylinders fail, all cylinders should be tested.  For subsequent 10-year service, alteration of the inspected cylinders must be carried out, i.e. different cylinders must be inspected from those done in the previous service, if 100% of them were not inspected during the previous instance.  Ships of 10 years or older coming into Indian flag will be required to carry this test at the next scheduled dry-docking. |                                 |      |          |    |   |  |  |
| В  | <u>Fixed CO2 system:</u> Every ten years - All discharge pipe lines shall be tested to a pressure of a maximum working pressure of the respective sections or as specified by the manufacturer, whichever is higher.   |                                 |      |          |    |   |  |  |
| С  | The weekly, Monthly, Quarterly and Annual routine maintenance and inspections as specified in MSC.1/Circ.1432 shall be ensured, as minimum, for all systems of Fixed Gas extinguishing systems, including for the Fixed CO2 systems.   |                                 |      |          |    |   |  |  |


### Annex 1


# Part 1 - Basic Testing





# Part 2 - Extended Testing





## **ANNEX 2**

### **Safety Management System:**

Maintenance and inspection should be carried out in accordance with the ship's maintenance plan having due regard to ensuring the reliability of the system. The onboard maintenance plan should be included in the ship's safety management system and should be based on the system manufacturer's recommendations.

### **Operational readiness:**

All fire protection system and appliances should be, at all times, in good order and available for immediate use while the ship is in service. If a fire protection system is under repair, then suitable arrangements acceptable to the Recognized Organization that issued the pertinent Safety Certificate shall be made to ensure safety is not diminished.

In cases where the Recognized Organization which has issued the vessel's Statutory Certificate determines that the equipment does not comply with the requirements of the corresponding mandatory regulations, they must approach the Administration for an authorization for the issuance of the relevant Conditional Statutory Certificate prior to permit the vessel to operate. Any vessel in a port or dry-dock or anchorage or temporarily immobilized due to some reason, shall be construed to be as a vessel under operation.

## **Competent Persons/ Crew members:**

Certain maintenance procedures and inspections may be performed by competent crew members, while others should be performed by authorised service agencies. The onboard maintenance plan should indicate which parts of the recommended inspections and maintenance should be completed by trained personnel.

<u>Competent Crew members</u> in this case is to be construed as that the basic and extended services may be carried out onboard ships under the supervision of an experienced person holding a Merchant Shipping STCW II/2 or III/2 unlimited certificate of competency and an Advanced Fire Fighting certificate.

<u>Competent Person</u> is a person specifically trained and authorised for the specific service / maintenance activity by the equipment manufacturer.

### **Records:**

The Master and / or the Chief Engineer as the case may be, should ensure that the indicated weekly, monthly, quarterly, annual, two-yearly, five-yearly and ten yearly inspections are taken for the specified equipment, if provided. Records of the

inspections should be maintained on board the ship in hard or soft form. In cases where the inspections and maintenance are carried out by trained service technicians other than the ship's crew, inspection reports / certificate duly endorsed by the competent person should be retained onboard for verification, with the identity of such person being clearly decipherable.